



[www.sjra.net](http://www.sjra.net)

**ADDENDUM NO. 1  
CSP # 19-0001**



1/15/19

Date: January 15, 2019  
To: All Interested Parties  
From: Grady Garrow, CPPB  
Senior Buyer

Re: **CSP No. 19-0001 Rehabilitation of Water Well No's 25 & 31**

The following additions, deletions, changes or clarifications to CSP No. 19-0001 are hereby made a part of the originally issued documents for the above referenced project as fully and as completely as though the same were included therein.

**CSP #19-0001**

**Question:** The data sheets for both Well 25 and Well 31 list the shaft size as 1-15/16" with 3-1/2" oil tubing. The nominal size oil tubing used with 1-15/16" shaft is normally 3" (ID) (with 3-1/2" OD). Please clarify whether the 3-1/2" oil tubing is the nominal size (3" ID) or the OD.

**Answer:** 3" ID / 3-1/2" OD.

All provisions which are not so amended or supplemented remain in full force and effect.

Please acknowledge receipt of this addendum with signature and date and return with completed Proposal/Quotation. Failure to do so may cause your Proposal to be considered non-responsive.

***Receipt of this Addendum No. 1 is hereby acknowledged***

\_\_\_\_\_  
**Authorized Signature**

\_\_\_\_\_  
**Date**

\_\_\_\_\_  
**Company Name**